

STANDARD PLAN RELEASE SUMMARY (SPR)

Architecture, Engineering, and Construction Division

Building Type: Independence Series Meetinghouse

IPC-MH-10-06 [130 Chapel Size Meetinghouse]

Release Date: July 2016

Release Number: 6

Summarized below is a list of modifications made to the Standard Plans, which are applicable to the Building Design indicated. This list is not intended to be exhaustive or detailed in nature, but is a tool for Project Managers and their consultants to quickly identify the changes made since the last Standard Plan Update. The Priority Level is intended to identify four levels of implementation for current projects in the late design phase or construction phase. Current projects in the planning phase or early design phase should incorporate all Changes where applicable.

Level 1 - Essential Priority: Implement Change even if building is near Substantial Completion;

Level 2 - Important Priority: Implement Change even when Change may require minor additional cost - if Change will require significant additional cost or time, Change is left to PM's discretion;

Level 3 - Standard Priority: Implement Change at PM's sole discretion.

Level 4 - Low Priority: Implement Change as appropriate to phase of project. Change should not affect cost or schedule.

Format Note: ~~Red struckthrough text~~ addresses items to be removed from drawings.

Item Number	Affected Sheet No's and Detail No's	Description	Priority Level
1	A103, 1/A103	MAIN FLOOR WALL TYPES AND WALL TYPES PLAN sheet: <u>WALL TYPES</u> : Deleted wall type XA8-B ; added wall sheathing to wall type XA8-H; corrected wall dimension in multiple wall types. MAIN FLOOR WALL TYPES PLAN : Corrected multiple wall types.	2
2	1/A121, A/A121	ROOF PLAN : Added new ladder anchor with detail reference near intersection of Gridlines '1' and 'D'. ROOF ACCESS LADDER ANCHOR : Added new detail.	2
3	E/A123, F/A123	TYPICAL EAVE DETAIL : Revised truss blocking and ventilation provision. INSULATION/VAPOR RETARDER : Added new detail (two options given).	2
4	A301	BUILDING SECTIONS sheet: Revised soffit ventilation provision; clarified insulation installations.	2
5	A/A311, B/A311, C/A311, D/A311, H/A311	WALL SECTION : Revised soffit ventilation provision. WALL SECTION : Revised soffit ventilation provision. WALL SECTION : Added missing insulation. CANOPY CONNECTION : Added missing insulation. CANOPY CONNECTION: Deleted unused section.	2
6	J/A411	FONT DRAIN : Added new detail with framed note clarifying bonding provisions.	2
7	U/A501, V/A501	FONT HANDRAIL BRACKET : Added new detail clarifying bonding provisions. HOLLOW METAL FRAME : Added new detail clarifying bonding provisions.	2
8	A601	FINISH SCHEDULE : Renumbered and reordered row information for 125 [124] SERVING AREA and 124 [125] MATERIALS CENTER; <u>CEILING HEIGHT</u> column: changed ceiling height CH 4 [4] for room numbers 104, 113, and 114.	2

Item Number	Affected Sheet No's and Detail No's	Description	Priority Level
9	A602	<p>DOOR SCHEDULE: Deleted <i>ROOM column</i>; Revised frame designations in <u>FRAME, PROFILE</u>; Corrected detail references and revised remarks for all folding partitions.</p> <p>FRAME PROFILES: Redesignated frames to be <i>FA</i> [FM] and <i>FB</i> [FA]; clarified frame dimensions.</p>	2
10	1/S102	<p>WALL TYPE PLAN: Corrected multiple wall types; clarified wall sheathing placements; removed <i>redundant roof framing information</i>.</p>	2
11	1/S105	<p>OVERBUILD ROOF FRAMING PLAN ENLARGED: Corrected designation for Gridline <i>'2'</i>['1']; clarified overbuild trusses parallel to Gridline '1'; corrected bottom of beam elevation 107'- <i>4</i>[2] 5/8" for beam BM-1 along Gridline '1'; corrected bottom of beam elevation 107'- 4 <i>5/8</i>" for beam BM-1 over outside vestibule doors; clarified double TR-5 truss for attaching outlookers at gable end over extended vestibule portion of building.</p>	2
12	S521 G/S521, H/S521, P/S521, Q/S521, R/S521	<p>ROOF FRAMING DETAILS sheet: Clarified multiple detail titles.</p> <p>TRUSS TO WOOD BEAM: Revised truss blocking for soffit ventilation upgrade.</p> <p>TRUSS TO STUD WALL: Revised truss blocking for soffit ventilation upgrade.</p> <p>BLOCKING CONDITION BETWEEN ROOF TRUSSES AT EXTERIOR WALLS: Revised truss blocking for soffit ventilation upgrade.</p> <p>BLOCKING CONDITION BETWEEN ROOF TRUSSES AT INTERIOR WALLS: Revised truss blocking for soffit ventilation upgrade.</p> <p>ROOF FRAMING AT ENTRY: Clarified multiple elevation references.</p>	2
13	S522	<p>ROOF FRAMING DETAILS sheet: Clarified multiple detail titles.</p>	2
14	S602	<p>STRUCTURAL SCHEDULES sheet: <u>SCHEDULE C</u>: Schedule Note 2: Corrected reference <i>A/S002</i> [A/S602].</p>	2
15	A/FS501 (all options)	<p>RISER SCHEMATIC: Changed fire sprinkler riser water supply piping from <i>jointed-assembly</i> to one-piece stainless steel in-building riser; revised related keyed detail notes.</p>	2